GENERAL NOTES

PIPES — INSULATION & HEATING
ALL PIPES AS INDICATED SHALL BE INSULATED AND
HEAT TRACED. THE INSULATION SHALL BE 3/4" FIBERGLASS
WOOLERS IN WITH A MINIMUM DENSITY OF 7.25 PUTL.

JOINTS. FITTINGS AND VALVE INSULATION SHALL BE

THE HEAT TRACING SHALL BE RATED AT 5 WATTS PER

HEAT CABLE SHALL BE EQUAL TO CHROMOLOX RTSR.

SODIUM HYPOCHLORITE - SINGLE LINE, PVC SCH 80

SODIUM HYPOCHLORITE — 3" PRODUCT LINE—POLYTHREAD SODIUM HYPOCHLORITE — 6" CONTAINMENT

SODIUM HYPOCHLORITE — DOUBLE CONTAINMENT

TANKS NO. 18 & 19
REFER TO SPEC'S AND DETAILS ON DWG. M-7 & M-11
SAME AS TANKS NO. 16 & 17 (INCLUDING COATINGS)

WASTE STORAGE PIPING - Sch 80 PVC and SDR 11 HDPE

UNLESS OTHERWISE NOTED.

PIPE HANGERS & SUPPORTS - WASTE SYSTEM-REFER TO SPEC'S M-9

FOOT @ 240 VOLTS USING A WRAPPING PITCH OF 7" ON BOTH 2" AND 3" PIPES. ALL RECIRCULATION LINES SHALL USE HEAT TRACING WITH A FLUOROPOLYMER JACKET.

JACKET SHALL BE .016 INCH ALUMINUM COVER WITH MASTIC LAPS, AND SOFT ALUMINUM BANDS ON 12" CENTERS FOR BUTT

COATED WITH A METHOD RECOMMENDED BY THE MANUFACTURER.

